

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K1502B(S)	VOLTS:	208 1P	240 1P
TAG: 6HK16501506	HTR WATTS:	10800	14400
PAGE 3 OF 5	HTR AMPS:	51.9	60.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AE 30B	25.8-43.3	30-45	28.1-47.9	30-50
AE 36B,36C,42C	27.7-43.3	30-45	30.0-47.9	30-50
AE 48C,48D,60C,60D	30.2-43.3	35-45	32.5-47.9	35-50
AVC 30B	25.4-43.3	30-45	27.6-47.9	30-50
AVC 36B,36C,42C	27.9-43.3	30-45	29.6-47.9	30-50
AVC 48C,48D,60C,60D	30.8-43.3	35-45	32.7-47.9	35-50
SINGLE POINT				
AE 30B	69.0	7	75.9	80
AE 36B,36C,42C	70.9	80	77.7	80
AE 48C,48D,60C,60D	73.4	80	80.2	90
AVC 30B	68.7	70	75.4	80
AVC 36B,36C,42C	71.2	80	77.4	80
AVC 48C,48D,60C,60D	74.0	80	80.5	90

