

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K1504	VOLTS:	208 3P	240 3P
TAG: 6HK06501525	HTR WATTS:	10800	14400
page 1 of 2	HTR AMPS:	30.0	34.6

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AHR 24B	39.1	40	43.2	45
AHR 30B, 36B	41.7	45	46.2	50
AHR 42C, 48D, 60D	41.7	45	46.2	50
AHE 22B, 24B, 30B	41.0	45	44.9	50
AHE 34C, 36C, 42D	42.6	45	46.6	50
AHE 48D, 60D	45.0	50	48.9	50
AP 30B	40.4	45	44.3	45
AP 36B / AE 30B	40.8	45	44.7	45
AP 36C, 37C	40.3	45	44.2	45
AP 42C	41.0	45	45.0	45
AP 48C, 48D	41.1	45	45.1	50
AP 60C, 60D	42.6	45	46.6	50
AE 36B,36C,42C	42.3	45	48	50
AE 48C,48D,60C,60D	44.3	45	50	50

