

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K1802(S)	VOLTS:	208-1P	240-1P
TAG: 6HK1(2)6501806	HTR WATTS:	13000	17300
PAGE 2 OF 3	HTR AMPS:	62.5	72.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AP 36B	39.0-42.3	40-45	43.1-46.4	45-50
AP 36C, 37C	39.0-41.8	40-45	43.1-45.9	45-50
AP 42C	39.0-			
AP 48C, 48D	39.0-42.6	40-45	43.1-46.8	45-50
AP 60C, 60D	39.0-44.1	40-45	43.1-48.3	45-50
SINGLE POINT	81.4	90	89.7	90
AP 36B	80.9	90	89.2	90
AP 36C, 37C	81.6	90	89.9	90
AP 42C	81.8	90	90.0	90
AP 48C, 48D	83.3	90	91.5	150
AP 60, 60D				

