

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K2002B(S)	VOLTS:	208-1P	240-1P
TAG: 6HK16502006	HTR WATTS:	14400	19200
PAGE 2 OF 3	HTR AMPS:	69.2	80.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AP 36B	43.3-46.6	45-50	47.9-51.2	50-60
AP 36C, 37C	43.3-46.1	45-50	47.9-50.7	50-60
AP 42C	43.3-46.8	45-50	47.9-51.4	50-6
AP 48C, 48D	43.3-47.0	45-50	47.9-51.5	50-60
AP 60C, 60D	43.3-48.5	45-50	47.9-53.0	50-60
SINGLE POINT	89.8	90	98.9	100
AP 36B	89.3	90	98.4	100
AP 36C, 37C	90.0	90	99.2	100
AP 42C	90.2	100	99.3	100
AP 48C, 48D	91.7	100	100.8	110
AP 60C, 60D				

