

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K2005A	VOLTS:		480-3P
	HTR WATTS:		19200
	HTR AMPS:		23.1

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AHR 36B			31.3	35
AHR 42C, 48D, 60D			31.3	35
AHE 34C, 36C, 42D			31.4	35
AHE 48D, 60D			32.6	35
AHV 36C, 42D			30.9	35
AHV 48D, 60D			31.9	35
AP 36B			30.5	35
AP 36C, 37C			30.3	35
AP 42C			30.6	35
AP 48C, 48D			30.7	35
AP 60C, 60D			31.4	35
AE 36B, 36C, 42C			31.3	35
AE 48C, 48D, 60C, 60D			32.3	35

