INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WRX0705		**VOLTS:**	480-3P
TAG: RXBH-17,24A07D		**HTR WATTS:**	7200
		HTR AMPS:	8.7

	EQUIPMENT MODEL NO	**MCA**	**MOCP**
	RHSA/RHSL 30-36(17,21)	13.0	15
	RHSA/RHSL 42-60(21,24)	14.0	15
	UHSA/UHSL 30-36(17,21)	13.0	15
	UHSA/UHSL 42-60(21,24)	14.0	15

WARREN TECHNOLOGY