

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WRX0705A	VOLTS:		480 3P
	HTR WATTS:		7200
page 1 of 2	HTR AMPS:		8.7

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
UHSA/SL 18-36 (17, 21)			13.0	15
UHSA/SL 42-60 (21, 24)			15.0	15
UHLA/LL 18-36 (17)			13.0	15
UHLA/LL 42-60 (21, 24)			14.0	15
RHSA/SL 18-36 (17, 21)			13.0	15
RHSA/SL 42-60 (21, 24)			15.0	15
RHLA/LL 18-36 (17)			13.0	15
RHLA/LL 42-60 (21, 24)			14.0	15
RHKA/KL 18-24 (17)			13.0	15
RHKA/KL 30-60 (17, 21, 24)			16.0	20
RHPL 24-36 (21)			13.0	15
RHPL 48-60 (24)			14.0	15
RHPN 24 (21)			12.0	15
RHPN 36-60 (24)			14.0	15

