

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WRX1502S(B/X)	VOLTS:	208-1P	240-1P
TAG: RXBH17,24A-15J / RXBH-1724A15J	HTR WATTS:	10800	14400
PAGE 4 OF 4	HTR AMPS:	17.3-34.6	20.0-40.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
DUAL CIRCUIT				
RH1V 3617	28-44	30-45	31-50	35-50
RH1V 3621,4821,6021	28-44	30-45	31-50	35-50
RH1V 4824,6024	31-44	35-45	34-50	35-50
RH2V 3624,4824,6024	28-44	30-45	32-50	35-50
RHMV 2421 HEAC	28-44	30-45	31-50	35-50
RHMV 3617	26-44	30-45	30-50	30-50
RHMV 6021,6024	28-44	30-45	32-50	35-50
RH2V 4824,6024 HT	28-44	30-45	32-50	35-50
FH 3617,3621,4821,6021 TTS	27-44	30-45	31-50	35-50
FH 4824,6024 TTS	30-44	30-45	33-50	35-50
FH 3017,3617,3621 TPS	25-44	25-45	29-50	30-50
FH 4221,4821,4824,6024 TPS	29-44	30-45	32-50	35-50
RV050418				

