

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WRX2002S(B/X)	VOLTS:	208-1P	240-1P
TAG: RXBH17,24A-20J	HTR WATTS:	14400	19200
PAGE 1 OF 2	HTR AMPS:	69.2	80.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
SINGLE CIRCUIT				
RHLA/RHLL/UHLA/UHLL 42-60(21,24)	93	100	106	110
RHSA/RHSL/UHSA/UHSL 42-48(21,24)	92	100	105	110
RHKA/RHKL 42-60(21,24)	93	100	106	110
RHPL 48-60(24)/RHPN 36-60(24)	93	100	107	110
HFE 42-60(21,24)	94	100	108	110
DUAL CIRCUIT				
RHLA/RHLL/UHLA/UHLL 42-60(21,24)	44-49	45-50	50-56	50-60
RHSA/RHSL/UHSA/UHSL 42-48(21,24)	44-49	45-50	50-56	50-60
RHKA/RHKL 42-60(21,24)	44-49	45-50	50-56	50-60
RHPL 48-60(24)	44-50	45-50	50-57	50-60
HFE 42-60(21,24)	44-51	45-60	50-58	50-60

