

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM0505A	VOLTS:		480-3P
	HTR WATTS:		4800
	HTR AMPS:		5.8

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
TEM3A0 B30, B36			8.8	15
TEM3A0 C42, C48			8.9	15
TEM3A0 C60			11.2	15
TEM4A0 B24, B30, B36, C36,C37			8.9	15
TEM4A0 C42			9.8	15
TEM4A0 C48, C60			11.2	15
TEM6A0 B24, B30			9.0	15
TEM6A0 C36, C42			9.9	15
TEM6A0 C48, D48, D60			11.5	15
TEM8A0 B24, B30			9.0	15
TEM8A0 C36, C42			12.6	15
TEM8A0 C48, C60			10.8	15
TEM8A0 D48, D60			10.4	15

