

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM0804	VOLTS:	208-3P	240-3P	
	HTR WATTS:	5760	7680	
	HTR AMPS:	16.0	18.5	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
TEM3A0 B18, B24	21.6	25	24.8	25
TEM3A0 B30, B36	23.1	25	26.3	30
TEM3A0 C42, C48	23.3	25	26.4	30
TEM3A0 C60	27.9	30	31	35
TEM4A0 B18, B24	21.6	25	24.8	25
TEM4A0 B30, C36	23.3	25	26.4	30
TEM4A0 C42	25.1	30	28.3	30
TEM4A0 C48, C60	27.9	30	31.0	35
TEM6A0 B24, B30 / TEM8A0 B24, B30	23.5	25	26.6	30
TEM6A0 C36, C42	25.4	30	28.5	30
TEM6A0 D48, D60	28.5	30	31.6	35
TEM8A0 C36, C42	25.4	30	28.5	30
TEM8A0 C48, C60	27	30	30.1	35
TEM8A0 D48, D60	26.3	30	29.4	30

