

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM1005		VOLTS:		480-3P		
		HTR WATTS:		9600		
		HTR AMPS:		11.5		
EQUIPMENT MODEL NO			MCA	MOCP	MCA	MOCP
	TEM3A0 B30, B36				14.4	15
	TEM3A0 C42, C48				14.4	15
	TEM3A0 C60				14.4	15
	TEM4A0 B30, B36, C36, C37				14.4	15
	TEM4A0 C42				14.4	15
	TEM4A0 C48, C60				14.4	15
	TEM6A0 B24, B30				14.4	15
	TEM6A0 C36, C42				14.4	15
	TEM6A0 C48, D48, D60				14.4	15
	TEM8A0 B24, B30, C36, C42, C48, C60, D48, D60				14.4	15

