

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM1504	VOLTS:	208-3P	240-3P
TAG: BAYHTR3515LUG	HTR WATTS:	10800	14400
	HTR AMPS:	30.0	34.6

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
TEM3A0 B30, B36	40.6	45	46.4	50
TEM3A0 C42, C48	40.8	45	46.5	50
TEM3A0 C60	45.4	50	51.1	60
TEM4A0 B30, C36	40	40	46	50
TEM4A0 C42	42	45	48	50
TEM4A0 C48, C60	44	45	50	50

