INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM2002B	**VOLTS:**	208-1P	240-1P
TAG: BAYHTR1519(20)(21)BRK	**HTR WATTS:**	14400	19200
	HTR AMPS:	34.6-34.6	40-40

	EQUIPMENT MODEL NO	**MCA**	**MOCP**	**MCA**	**MOCP**
	TEM3A0 C60	52-44	60-45	58-50	60-50
	TEM4A0 C60	51-43	60-45	58-50	60-50

WARREN TECHNOLOGY