

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WEM2002BV		VOLTS:	208 - 1P	240 - 1P		
		HTR WATTS:	14400	19200		
BAYHTR1522(23)BRK		HTR AMPS:	34.6 - 34.6	40 - 40		
EQUIPMENT MODEL NO			MCA	MOCP	MCA	MOCP
	TEM6A0 C42 SA		49-43	50-45	55-50	60-50
	TEM6A0 D48, D60 SA		52-43	60-45	60-59	60-60
	TEM8A0 C36, C42 SA		49-43	50-45	55-50	60-50
	TEM8A0 C48, C60 SA		50-43	50-45	57-50	60-50
	TEM8A0 D48, D60 SA		50-43	50-45	56-50	60-50
	TEM4A0 C37 SB		46-43	50-45	53-50	60-50
	TEM4A0 C42 SB		48-43	50-45	55-50	60-50
	TEM4A0 C48, C60 SB		51-43	60-45	58-50	60-50
	TEM6A0 C42 SB		49-43	50-45	55-50	60-50
	TEM6A0 C48, D48, C60, D60 SB		52-43	60-45	59-50	60-50
	TEM8A0 C42 SB		48-43	50-45	55-50	60-50
	TEM8A0 C48, D48, C60, D60 SB		50-43	50-45	57-50	60-50

