

# TRANE CROSS REFERENCE

## WTE SERIES

WARREN MODEL NO.	TRANE MODEL NO.	KW @240/1	FOR USE WITH	AMPS	STEPS
WTE0502	BAYHTR1305000	4.8	2TEH3F 18A-60A	20.0	1
WTE0802	BAYHTR1308000	7.68	2TEH3F 18A-60A	32.0	2
WTE1002	BAYHTR1310000	9.6	2TEH3F 30A-60A	40.0	2
WTE0502B	BAYHTR1305BRK	4.8	2TEH3F 18A-60A	20.0	1
WTE0802B	BAYHTR1308BRK	7.68	2TEH3F 18A-60A	32.0	2
WTE1002B	BAYHTR1310BRK	9.6	2TEH3F 30A-60A	40.0	2
WTE1502B	BAYHTR1315BRK	15.36	2TEH3F 36A-60A	60.0	3
WTE2002B	BAYHTR1319BRK	19.2	2TEH3F 36A-60A	80.0	4
WTE0502PD	BAYHTR1305PDC	4.8	2TEH3F 18A-60A	20.0	1
WTE0802PD	BAYHTR1308PDC	7.68	2TEH3F 18A-60A	32.0	2
WTE1002PD	BAYHTR1310PDC	9.6	2TEH3F 30A-60A	40.0	2
WTE1004	* BAYHTR3310000	9.6	2TEH3F 30A-60A	23.1	2
WTE1504	* BAYHTR3315000	15.36	2TEH3F 36A-60A	37.0	3

000 = PIGTAIL POWER CONNECTIONS

BRK = CIRCUIT BREAKER(S)

PDC = PULL DISCONNECT

\* = 240/3 PHASE

### WARREN TECHNOLOGY

2050 W 73 ST \* P.O. BOX 5347 \* HIALEAH, FL 33016-9912 \* TEL: (305) 556-6933 \* FAX: (305) 557-6157

Website: warrenhvac.com Email: warren@warrenhvac.com