



CAUTION: Relays utilize 22VDC coils with AC to DC rectifiers. Do not use relay without rectifier. Replace with factory authorized parts only.

24VAC Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC

\*\*\*\*  
FIELD CONNECTION  
480VAC  
3Ø

Model	WEM-0505
Serial #	_____
Tag -	_____
Kilowatts	4.8
Volts-Ph-Hz	480/3Y/60
Control Volts	24.0
Steps	1
Heater Amps	5.8

**NOTE :**

- \* Replace "Service Loop" with SL075A
- \*\* Replace Auto-Reset with Therm-O-Disc type 60TX11-L165.
- \*\*\* 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.
- \*\*\*\* Power supply wiring per NEC & Local Codes. Suitable for at least 75°C. Use copper conductor wiring only.

Control Wiring \_\_\_\_\_  
 Power Wiring \_\_\_\_\_  
 Field Wiring \_\_\_\_\_

WEM0505

Rev. by : M. REEVES  
 Date : 02/27/15

# WARREN TECHNOLOGY