



CAUTION: Relays utilize 22VDC coils with AC to DC rectifiers. Do not use relay without rectifier. Replace with factory authorized parts only.

24VAC Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC

**NOTE :**

- \* Replace "Service Loop" with SL075B
- \*\* Replace Auto-Reset with Therm-O-Disc type 60TX11-L165.
- \*\*\* 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.
- \*\*\*\* Power supply wiring per NEC & Local Codes. Suitable for at least 75°C. Use copper conductor wiring only.

Model	WEM-0802B
Serial #	_____
Tag -	_____
Kilowatts	7.68
Volts-Ph-Hz	240/1/60
Control Volts	24.0
Steps	1
Heater Amps	32.0
Circuit Breaker	60

Control Wiring \_\_\_\_\_

Power Wiring \_\_\_\_\_

Field Wiring \_\_\_\_\_