



Model	WEM-1004
Serial #	_____
Tag -	_____
Kilowatts	9.6
Volts-Ph-Hz	240/3/ Δ /60
Control Volts	24.0
Steps	1
Heater Amps	23.1

NOTE :

- * Replace "Service Loop" with SL075B
- ** Replace Auto-Reset with Therm-O-Disc type 60TX11-L165.
- *** 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.
- **** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C. Use copper conductor wiring only.

Control Wiring _____
 Power Wiring _____
 Field Wiring _____

WEM1004

Rev. by : M. REEVES
 Date : 02/27/15

WARREN TECHNOLOGY