



FIELD
CONNECTION
240VAC
3 Ø

CAUTION: Relays utilize 22VDC coils with AC to DC
rectifiers. Do not use relay without rectifier.
Replace with factory authorized parts only.

24VAC Class 2 power source must not exceed
26.4VAC under any primary input voltage condition
per UL/NEC

Model	_____
Serial #	_____
Tag -	_____
Kilowatts	_____
Volts-Ph-Hz	_____
Control Volts	_____
Steps	_____
Heater Amps	_____

NOTE :

- ** Replace Auto-Reset with Therm-O-Disc type L155-333F
- *** 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.
- **** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C. Use copper conductor wiring only.

Control Wiring -----
Power Wiring _____
Field Wiring _____