



Model \_\_\_\_\_  
 Serial # \_\_\_\_\_  
 Tag - \_\_\_\_\_  
 Kilowatts \_\_\_\_\_  
 Volts-Ph-Hz \_\_\_\_\_  
 Control Volts \_\_\_\_\_  
 Steps \_\_\_\_\_  
 Heater Amps \_\_\_\_\_  
 Circuit Breakers \_\_\_\_\_

WKS-0605 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 6.0 \_\_\_\_\_  
 480/3Y/60 \_\_\_\_\_  
 24.0 \_\_\_\_\_  
 1 \_\_\_\_\_  
 7.2 \_\_\_\_\_  
 N/A \_\_\_\_\_

NOTE :

- \*Replace service loops with SL-075A
- \*\* Replace Auto-Reset with Therm-O-Disc type F165-X
- \*\*\* Power supply wiring, per NEC & Local Codes. Suitable for at least 75°C.
- Use copper conductor wiring only.
- \*\*\*\* 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.

Control Wiring \_\_\_\_\_  
 Power Wiring \_\_\_\_\_  
 Field Wiring \_\_\_\_\_

WKS0605

Rev. by : M. REEVES  
 Date : 02/27/15

WARREN TECHNOLOGY