



Model WKS-1005A  
 Serial # \_\_\_\_\_  
 Tag - \_\_\_\_\_  
 Kilowatts 9.6  
 Volts-Ph-Hz 480/3Y/60  
 Control Volts 24.0  
 Steps 1  
 Heater Amps 11.5  
 Circuit Breakers N/A

**NOTE :**  
 \*Replace service loops with SL-075A  
 \*\* Replace Auto-Reset with Therm-O-Disc type F165-X  
 \*\*\* Power supply wiring per NEC & Local Codes. Suitable for at least 75°C.  
 Use copper conductor wiring only.  
 \*\*\*\* 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.

Control Wiring \_\_\_\_\_  
 Power Wiring \_\_\_\_\_  
 Field Wiring \_\_\_\_\_

WKS1005A

Rev. by : M. REEVES  
 Date : 02/27/15

WARREN TECHNOLOGY