



NOTE :

CAUTION – Contactors utilize 22–28VDC coils with AC to DC rectifiers. Do not use contactor without rectifier. Replace with factory authorized parts only.

– Contactor must always utilize AC–DC Rectifier with Time Delay as shown.

*Replace service loops with SL–075B

** Replace Auto–Reset with Therm–O–Disc type 60TX11–L165

*** 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.

**** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C.

Use copper conductor wiring only.

Control Wiring

Power Wiring

Field Wiring

Model	WKS-1081S
Serial #	
Tag -	
Kilowatts	10.8
Volts-Ph-Hz	208-1-60
Control Volts	24.0
Steps	2
Heater Amps	51.9
Circuit Breakers	See C.B. above

WKS1081S

Rev. by : M. REEVES
Date : 02/27/15

WARREN TECHNOLOGY