



NOTE :

CAUTION - Contactors utilize 22-28VDC coils with AC to DC rectifiers. Do not use contactor without rectifier. Replace with factory authorized parts only.

-Contactor must always utilize AC-DC Rectifier with Time Delay as shown.

*Replace service loops with SL-075B

** Replace Auto-Reset with Therm-O-Disc type 60TX11-L165

*** 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.

**** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C.

Use copper conductor wiring only.

Control Wiring
 Power Wiring
 Field Wiring

Model _____ WKS-2002B
 Serial # _____
 Tag - _____
 Kilowatts _____ 19.2
 Volts-Ph-Hz _____ 240-1-60
 Control Volts _____ 24.0
 Steps _____ 2
 Heater Amps _____ 80.0
 Circuit Breakers See C.B. above