



Model WKS-2005
 Serial # _____
 Tag - _____
 Kilowatts 18.5
 Volts-Ph-Hz 480 / 3 / 60
 Control Volts 24.0
 Steps 1
 Heater Amps 22.3
 Circuit Breakers N/A

NOTE :
 *Replace service loops with SL-075A
 ** Replace Auto-Reset with Therm-O-Disc type F165-X
 *** Power supply wiring, per NEC & Local Codes. Suitable for at least 75 C.
 Use copper conductor wiring only.
 **** 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.

Control Wiring _____
 Power Wiring _____
 Field Wiring _____

WKS2005

Rev. by : M. REEVES
 Date : 02/27/15

WARREN TECHNOLOGY