




WZJH

0502DP



HEATER - SECTION

Model WZH-0502DP

Serial # _____

Tag - _____

Kilowatts 5.00

Volts-Ph-Hz 240/1/60

Control Volts 24.0

Steps 1

Heater Amps 20.83

NOTE :

- * Replace "Service Loop" with SL-075B
- ** Replace Auto-Reset with Therm-O-Disc type 60TX11-L165.
- *** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C.

Use copper conductor wiring only.
Relays utilize 22VDC coils with AC to DC rectifiers.
Do not use relay without rectifier.
Replace with factory authorized parts only.
24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.

Control Wiring _____

Power Wiring _____

Field Wiring _____

Rev. by : M. REEVES

Date : 02/27/15

WARREN TECHNOLOGY

WZH0502DP