




WZJH

0502X



HEATER - SECTION

Model _____ WZH-0502X
 Serial # _____
 Tag - _____
 Kilowatts _____ 5.00
 Volts-Ph-Hz _____ 240/1/60
 Control Volts _____ 24.0
 Steps _____ 1
 Heater Amps _____ 20.83

- NOTE :
- * Replace "Service Loop" with SL-075B
 - ** Replace Auto-Reset with Therm-O-Disc type 60TX11-L165.
 - *** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C.
 - Use copper conductor wiring only.
 - Relays utilize 22VDC coils with AC to DC rectifiers. Do not use relay without rectifier.
 - Replace with factory authorized parts only.
 - 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.

Control Wiring _____
 Power Wiring _____
 Field Wiring _____

Rev. by : M. REEVES
 Date : 02/27/15

WARREN TECHNOLOGY

WZH0502X