



HEATER — SECTION

Model _____
 Serial # _____
 Tag — _____
 Kilowatts _____
 Volts—Ph—Hz _____
 Control Volts _____
 Steps _____
 Heater Amps _____

NOTE :

- * Replace "Service Loop" with SL-075B
- ** Replace Auto-Reset with Therm-O-Disc type 60TX11-L165.
- *** Power supply wiring per NEC & Local Codes. Suitable for at least 75 °C.
- Use copper conductor wiring only.
- Relays utilize 22VDC coils with AC to DC rectifiers. Do not use relay without rectifier.
- Replace with factory authorized parts only.
- 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.

Control Wiring _____
 Power Wiring _____
 Field Wiring _____