



**NOTE :**

- \* Replace "Service Loop" with SL-075B
- \*\* Replace Auto-Reset with Therm-O-Disc type 60TX11-L165.
- \*\*\* Power supply wiring per NEC & Local Codes.

Suitable for at least 75°C.

Use copper conductor wiring only.

Relays utilize 22VDC coils with AC to DC rectifiers.

Do not use relay without rectifier.

Replace with factory authorized parts only.

24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.

Control Wiring \_\_\_\_\_

Heater Amps \_\_\_\_\_

Heater Bredders \_\_\_\_\_

Power Wiring \_\_\_\_\_

Field Wiring \_\_\_\_\_

Model	WZH-1002S
Serial #	_____
Tag -	_____
Kilowatts	10.00
Volts-Ph-Hz	240/1/60
Control Volts	24.0
Steps	2
Heater Amps	41.66
Circuit Bredders	60/50

WZH1002S

Rev. by : M. REEVES  
Date : 02/27/15