



NOTE :

* Replace "Service Loop" with SL-075B

** Replace Auto-Reset with Therm-O-Disc type 60TX11-L165.

*** Power supply wiring per NEC & Local Codes.

Suitable for at least 75°C.

Use copper conductor wiring only.

Relays utilize 22VDC coils with AC to DC rectifiers.

Do not use relay without rectifier.

Replace with factory authorized parts only.

24VAC, Class 2 power source must not

exceed 26.4VAC under any primary input voltage

condition per UL/NEC.

Control Wiring

Power Wiring

Field Wiring

Model	WZH-2002S
Serial #	
Tag -	
Kilowatts	20.00
Volts-Ph-Hz	240/1/60
Control Volts	24.0
Steps	2
Heater Amps	83.33
Circuit Breakers	60/60/50

WZH2002S

Rev. by : M. REEVES
Date : 02/27/15