

**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

<b>MODEL NO:</b> WGM0502	<b>VOLTS:</b>	208-1P	240-1P
<b>TAG:</b> BAYEAC05LG1A	<b>HTR WATTS:</b>	3600	4800
* = A, T    page 2 of 2	<b>HTR AMPS:</b>	17.3	20.0

<b>EQUIPMENT MODEL NO</b>		<b>MCA</b>	<b>MOCP</b>	<b>MCA</b>	<b>MOCP</b>
	TAM9A0 A24, B30, C36, C42	26	30	29	30
	TAM9A0 C48	28	30	31	35
	TAM9A0 C60	30	30	33	35