INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM0504	**VOLTS:**	208 3P	240 3P
	HTR WATTS:	3600	4800
* = A, T page 2 of 2	**HTR AMPS:**	10.0	11.5

	EQUIPMENT MODEL NO	**MCA**	**MOCP**	**MCA**	**MOCP**
	TAM9A0 A24, B30, C36, C42	14.7	15	16.6	20
	TAM9A0 C48	15.6	20	17.5	20
	TAM9A0 C60	16.5	20	18.4	20

WARREN TECHNOLOGY