INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM1002	**VOLTS:**	208-1P	240-1P
TAG: BAYEAAC10LG1A	**HTR WATTS:**	7200	9600
*=A, T page 2 of 2	**HTR AMPS:**	34.6	40.0

	EQUIPMENT MODEL NO	**MCA**	**MOCP**	**MCA**	**MOCP**
	TAM9A0 A24, B30, C36, C42	48	50	54	60
	TAM9A0 C48	50	50	56	60
	TAM9A0 C60	51	60	58	60

WARREN TECHNOLOGY