

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM1002B	VOLTS:	208-1P	240-1P
TAG: BAYEAC10BK1A page 1 of 2	HTR WATTS:	7200	9600
* = A, T / NR = not recommended	HTR AMPS:	34.6	40.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
GAM5A(B)0 A18,A24,B30	47	50	54	60
GAM5A(B)0 B36,C42	48	50	55	60
GAM5A(B)0 C48	51	60	58	60
GAM5A(B)0 C60	53	60	60	60
*AM4AO A18	46	50	53	60
*AM4AO A24, A30, A36	45	45	53	60
*AM4AO B42, C48	47	50	54	60
*AM4AO C60	53	60	60	60
GAT2AO, GAM2AO B42	47	50	53	60
GAT2AO, GAM2AO C48	47	50	54	60
GAT2AO, GAM2AO C60	53	60	60	60
GAM2AO A18	46	50	53	60
GAM2AO A24, A30	45	45	52	60
GAM2AO A36	NR	NR	53	60

