

**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

<b>MODEL NO:</b> WGM1502B(S)	<b>VOLTS:</b>	208-1P	240-1P
<b>TAG:</b> BAYEABC15BK1A	<b>HTR WATTS:</b>	10800	14400
* = A, T page 2 of 2	<b>HTR AMPS:</b>	34.6-17.3	40.0-20.0

<b>EQUIPMENT MODEL NO</b>	<b>MCA</b>	<b>MOCP</b>	<b>MCA</b>	<b>MOCP</b>
TAM9A0 B30, C36, C42	48-22	50-25	54-25	60-25
TAM9A0 C48	50-22	50-25	56-25	60-25
TAM9A0 C60	51-22	60-25	58-25	60-25
<b>SINGLE POINT</b>				
TAM9A0 B30, C36, C42	69.3	70	79.4	80
TAM9A0 A24, B30, C36, C42	71.2	80	81.3	90
TAM9A0 A24, B30, C36, C42	72.9	80	83	90

