

**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

<b>MODEL NO:</b> WGM2002B(S)	<b>VOLTS:</b>	208-1P	240-1P
<b>TAG:</b> BAYEABC20BK1A	<b>HTR WATTS:</b>	14400	19200
* = A, T page 1 of 2	<b>HTR AMPS:</b>	34.6-34.6	40.0-40.0

<b>EQUIPMENT MODEL NO</b>	<b>MCA</b>	<b>MOCP</b>	<b>MCA</b>	<b>MOCP</b>
GAM5A(B)0 C48, C60	53-43	60-45	60-50	60-50
*AM4AO B42, C48, C60/ GAT2AO B42, C48, C60	53-43	60-45	60-50	60-50
GAM2AO B42, C48	53-43	60-45	54-50	60-50
GAM2AO C60	53-43	60-45	60-50	60-50
<b>SINGLE POINT</b>				
GAM5A(B)0 C48, C60	96	100	110	110
*AMA4AO B42	90	90	104	110
*AM4AO C48, C60	96	100	110	110
GAT2AO B42	90	90	104	110
GAT2AO C48, C60	96	100	110	110
GAM2AO B42, C48	96	100	104	110
GAM2AO C60	96	100	110	110

