


WEM

1002B



Model	WEM-1002B
Serial #	_____
Tag -	_____
Kilowatts	9.6
Volts-Ph-Hz	240/1/60
Control Volts	24.0
Steps	1
Heater Amps	40.0
Circuit Breaker	60

NOTE :
CAUTION - Contactors utilize 22-28VDC coils with AC to DC rectifiers. Do not use contactor without rectifier. Replace with factory authorized parts only.
-Contactor must always utilize AC-DC Rectifier with Time Delay as shown.

** Replace Auto-Reset with Therm-O-Disc type 60TX11-L165.

*** Replace Lock-Out Limit with 36TXV12 - 121°C To Reset Lock-Out Limit, Cycle Power To The Heater With Either The Circuit Breaker Or The Thermostat.

**** 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.

***** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C. Use copper conductor wiring only.

Control Wiring -----
Power Wiring _____
Field Wiring _____

WEM1002B

Rev. by : M. REEVES
Date : 02/10/20

WARREN TECHNOLOGY