

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS0302(B)	VOLTS:	208-1P	240-1P
TAG: HKSX(C)03XC	HTR WATTS:	2250	3000
14AA page 1 of 2	HTR AMPS:	10.8	12.5

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 18B,24B,30B / ARUF 18B,24B,25B,29B,30B,31B	16	20	18	20
ARPT 36C,36D / ARUF 36C,37C,37D,42C,43C,49C	18	20	20	20
ARPT 42D,48D / ARUF 43D,47D,48D,49D	18	20	20	25
ARPT 60D / ARUF 60D,61D	20	20	22	25
AVPTC / DVPTC 24B, 25B, 30C, 33C, 35B	18	20	21	25
AVPTC / DVPTC 29B, 31C, 36C, 37B, 37C,37D, 39C	20	20	22	25
AVPTC / DVPTC 42C, 42D, 48C, 49C, 49D	20	20	22	25
AVPTC / DVPTC 48D, 59C, 59D, 60D, 61D	22	25	24	25
ASPT 24B / ASUF 29B	17	20	19	20
ASPT 30C, 36C / ASUF 39C	17	20	20	20
ASPT 42D, 49C / ASUF 49C	20	20	22	25
ASPT 48D, 60D, 61D / ASUF 59C	22	25	24	25
072718R				

