

**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

<b>MODEL NO:</b> WXD1004X	<b>VOLTS:</b>	208 3P	240 3P
<b>TAG:</b> EHXB-3S10, EHxD-3S10	<b>HTR WATTS:</b>	7500	10000
PAGE 2 OF 2	<b>HTR AMPS:</b>	20.8	24.1

<b>EQUIPMENT MODEL NO</b>	<b>MCA</b>	<b>MOCP</b>	<b>MCA</b>	<b>MOCP</b>
DBH 0363D	45.8	50	49.8	50
DBH 0483D	50.8	60	54.8	60
DBH 0603D	55.1	60	59.1	60
DBH 0363B	43.5	45	47.5	50
DBH 0363C	43.5	45	47.5	50
DBH 0483B	47.3	50	51.3	60
DBH 0483C	48.7	50	52.7	60
DBH 0603B	51.4	60	55.4	60
DBH 0603C	53.0	60	57.0	60
NOTE: VALUES ABOVE ARE FOR THE ELECTRIC HEATER ONLY. REFER TO ELECTRICAL DATA TABLE ON BASE UNIT FOR ANY OPTIONAL EQUIPMENT INSTALLED.				

