

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WXD1005X	VOLTS:		480-3P
TAG: EHXB-4S10	HTR WATTS:		10000
	HTR AMPS:		12.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
DBC 0364B			17.2	20
DBC 0364C			17.2	20
DBC 0484B			17.2	20
DBC 0484C			18.0	20
DBC 0604B			16.9	20
DBC 0604C			18.0	20
DBC 0724S			18.7	20
DBC 0724V			18.7	20
NOTE: VALUES ABOVE ARE FOR THE ELECTRIC				
HEATER ONLY. REFER TO ELECTRICAL DATA TABLE				
ON BASE UNIT FOR ANY OPTIONAL EQUIPMENT				
INSTALLED.				

