

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WXD1504	VOLTS:	208-3P	240-3P
	HTR WATTS:	11250	15000
EHXB-3M15, EHXB-3M16	HTR AMPS:	31.2	36.1

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
DBC 0903S	50.5	60	56.5	60
DBC 0903V	46.6	50	52.6	60
DBC 1023S	50.5	60	56.5	70
DBC 1023V	46.6	50	52.6	60
DBC 1203S	50.5	60	56.5	60
DBC 1203V	46.6	60	52.6	60
DBC 1503S	62.2	80	62.6	80
DBC 1503V	57.3	70	57.3	70
NOTE: VALUES ABOVE ARE FOR THE ELECTRIC				
HEATER ONLY. REFER TO ELECTRICAL DATA TABLE				
ON BASE UNIT FOR ANY OPTIONAL EQUIPMENT				
INSTALLED.				

