

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WXD1505	VOLTS:			480 3P
TAG: EHXB-4M15, EHXB-4M16	HTR WATTS:			15000
	HTR AMPS:			18.0
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
DBC 0904S			27.9	30
DBC 0904V			26.2	30
DBC 1024S			27.9	30
DBC 1024V			26.2	30
DBC 1204S			27.9	30
DBC 1204V			26.2	30
DBC 1504S			31.3	40
DBC 1504V			29.0	35
NOTE: VALUES ABOVE ARE FOR THE ELECTRIC				
HEATER ONLY. REFER TO ELECTRICAL DATA TABLE				
ON BASE UNIT FOR ANY OPTIONAL EQUIPMENT				
INSTALLED.				

