**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

| | | | |
|---|---|---|---|
| **MODEL NO:** WXD2002X | **VOLTS:** | 208 1P | 240 1P |
| **TAG:** EHXD-1S22 | **HTR WATTS:** | 15000 | 20000 |
| | **HTR AMPS:** | 72.2 | 83.3 |

| | **EQUIPMENT MODEL NO** | **MCA** | **MOCP** | **MCA** | **MOCP** |
|---|---|---|---|---|---|
| | DBC0481D | 98.9 | 100 | 113.0 | 125 |
| | DBC0601D | 98.9 | 100 | 113.0 | 125 |
| | DBH0481D | 123.0 | 125 | 137.0 | 150 |
| | DBH0601D | 131.0 | 150 | 145.0 | 150 |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | NOTE: VALUES ABOVE ARE FOR THE ELECTRIC | | | | |
| | HEATER ONLY. REFER TO ELECTRICAL DATA TABLE | | | | |
| | ON BASE UNIT FOR ANY OPTIONAL EQUIPMENT | | | | |
| | INSTALLED. | | | | |

**WARREN TECHNOLOGY**