

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WXD2004	VOLTS:	208 3P	240 3P
	HTR WATTS:	15000	20000
	HTR AMPS:	41.6	48.1

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
DBC 0903S	63.4	70	71.5	80
DBC 0903V	59.5	60	67.6	70
DBC 1023S	63.4	70	71.5	80
DBC 1023V	59.5	60	67.6	70
DBC 1203S	63.4	70	71.5	80
DBC 1203V	59.5	60	67.6	70
DBC 1503S	69.5	70	77.6	80
DBC 1503V	63.4	70	71.5	80
NOTE: VALUES ABOVE ARE FOR THE ELECTRIC				
HEATER ONLY. REFER TO ELECTRICAL DATA TABLE				
ON BASE UNIT FOR ANY OPTIONAL EQUIPMENT				
INSTALLED.				

