

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WXD2004X	VOLTS:	208 3P	240 3P
TAG: EHXB-3S20, EHxD-3S22	HTR WATTS:	15000	20000
	HTR AMPS:	41.5	48.1

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
DBC 0483D	60.5	70	68.5	70
DBC 0603D	60.5	70	68.5	70
DBC 0483B	56.1	60	64.1	70
DBC 0483C	57.9	60	65.8	70
DBC 0603B	55.9	60	63.8	70
DBC 0603C	57.9	60	65.8	70
DBC 0723S(V)	59.4	60	67.3	70

NOTE: VALUES ABOVE ARE FOR THE ELECTRIC HEATER ONLY. REFER TO ELECTRICAL DATA TABLE ON BASE UNIT FOR ANY OPTIONAL EQUIPMENT INSTALLED.

