

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WXD2005	VOLTS:		480 3P
	HTR WATTS:		20000
	HTR AMPS:		24.06

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
DBC 0904S			35.5	40
DBC 0904V			33.7	35
DBC 1024S			35.5	40
DBC 1024V			33.7	35
DBC 1204S			35.5	40
DBC 1204V			33.7	35
DBC 1504S			38.3	40
DBC 1504V			35.5	40
NOTE: VALUES ABOVE ARE FOR THE ELECTRIC HEATER ONLY. REFER TO ELECTRICAL DATA TABLE ON BASE UNIT FOR ANY OPTIONAL EQUIPMENT INSTALLED.				

