

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WXD3004	VOLTS:	208 3P	240 3P
TAG: EHXB-3M30, EHXB-3M31	HTR WATTS:	22500	30000
	HTR AMPS:	62.5	72.2

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
DBC 0903S	89.6	90	102	110
DBC 0903V	85.7	90	97.7	100
DBC 1023S	89.6	90	102	110
DBC 1023V	85.7	90	97.7	100
DBC 1203S	89.6	90	102	110
DBC 1203V	85.7	90	97.7	100
DBC 1503S	95.7	100	108	110
DBC 1503V	89.6	90	102	110
NOTE: VALUES ABOVE ARE FOR THE ELECTRIC				
HEATER ONLY. REFER TO ELECTRICAL DATA TABLE				
ON BASE UNIT FOR ANY OPTIONAL EQUIPMENT				
INSTALLED.				

