

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WXD3005	VOLTS:		480 3P
TAG: EHXB-4M30, EHXB-4M31	HTR WATTS:		30000
	HTR AMPS:		36.1

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
DBC 0904S			50.5	60
DBC 0904V			48.7	50
DBC 1024S			50.5	60
DBC 1024V			48.7	50
DBC 1204S			50.5	60
DBC 1204V			48.7	50
DBC 1504S			53.4	60
DBC 1504V			50.5	60
NOTE: VALUES ABOVE ARE FOR THE ELECTRIC HEATER ONLY. REFER TO ELECTRICAL DATA TABLE ON BASE UNIT FOR ANY OPTIONAL EQUIPMENT INSTALLED.				

