

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS1005A	VOLTS:		480-3
	HTR WATTS:		9600
page 2 of 2	HTR AMPS:		11.6

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ASPT 25B, 29B			17.4	20
ASPT 33C, 39C, 47C			16.9	20
ASPT 35B, 37B, 37C			17.3	20
ASPT 49C			18.1	20
ASPT 59C			18.4	20
ASPT 49D, 61D			18.8	20
AMST 24B,30B,36B,42C			17.4	20
AMST 36C			18.1	20
AMST 48C,48D,60D			18.8	20
DMVT 24B,30B			17.6	20
DMVT 36B,42C,48C			18.6	20
DMVT 48D,60D			19.9	20
030923R				

