

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS1005A	VOLTS:		480-3P
	HTR WATTS:		9600
page 1 of 2	HTR AMPS:		11.6

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 24B,30B / ARUF 18B,24B,25B,29B,30B,31B			15.7	20
ARPT 36C,36D / ARUF 36C,37C,37D,42C,43C,49C			16.4	20
ARPT 42D,48D / ARUF 43D,47D,48D,49D			16.7	20
ARPT 60D / ARUF 60D,61D			17.4	20
AVPTC / DVPTC 24B,25B,30C,33C,35B			16.9	20
AVPTC / DVPTC 29B,31C,36C,37B,37C,37D,39C			17.8	20
AVPTC / DVPTC 42D,48C,48D,49C,49D			17.8	20
AVPTC / DVPTC 59C,59D,60D,61D			18.8	20
ASPT 24B / ASUF 29B			15.9	20
ASPT 30C, 36C / ASUF 39C			16.5	20
ASPT 42D			17.5	20
ASPT 48D, 60D, 61D / ASUF 59D			18.7	20
ASUF 49C			17.8	20
072618R				

